

Installation Instructions

Class 2 Low Voltage Dimmable Driver / Enclosure

READ PRIOR TO ATTEMPTING INSTALLATION
ALWAYS TURN OFF MAIN POWER BEFORE INSTALLATION
INSTALLATION SHOULD BE CARRIED OUT BY YOUR LOCAL ELECTRICIAN


| Item No. | Description |
|---------------|-----------------------|
| NAPKED-5040HW | 120V / 12V 40W Driver |
| NAPKED-5060HW | 120V / 12V 60W Driver |
| NATLED-5040HW | 120V / 24V 40W Driver |
| NATLED-5075HW | 120V / 24V 75W Driver |

⚠ WARNING - This equipment is intended to be installed only by qualified personnel. The installation must be made in accordance with the current edition to the National Electric Code and all applicable state and local building codes. The final installation must be approved by the appropriate qualified electrical/building inspector(s). Improper installation may result in a fire or electrical hazard. Be sure the electrical power to the circuit has been disconnected before installing this electrical system.

⚠ AVERTISSEMENT - Cet équipement est destiné à être installé uniquement par du personnel qualifié. L'installation doit être faite en conformité avec l'édition actuelle du Code national de l'électricité et toutes étatiques et locales codes du bâtiment applicables. L'installation finale doit être approuvée par l'inspecteur en électricité / bâtiment qualifié approprié(s). Une mauvaise installation peut entraîner un incendie ou un risque électrique. Soyez sûr de la puissance électrique vers le circuit a été coupée avant l'installation de ce système électrique.



PACKAGING CONTENTS




Driver / Enclosure

- a. Strain Relief
- b. 10' Power Line Connector

A.



B.



CAUTION:

- All installations should comply with National and local electrical codes
- This is intended to be installed with compatible Nora Lighting 12V or 24V systems
- Read all instructions thoroughly before starting installation
- Turn off power before installing the system

WIRING INSTRUCTIONS:

1. Fasten driver housing using two screws (not included) through key hole slots. (Figure 1)
2. Attach ground wire to enclosure.
3. Connect line voltage wires to driver's black and white input leads per local electrical code. (Figure 2)
4. Connect low voltage wires to driver's red and black output leads using supplied strain relief. (Figure 2)
5. **OPTIONAL:** Connect Nora's 10' power line connector (included) to driver's output leads.
6. Secure driver box cover.

NOTE: Consult Nora website for compatible dimmers.

