



(2)

(8)

T&S BRASS AND BRONZE WORKS, INC.

2 Saddleback Cove / P.O. Box 1088 Travelers Rest, SC 29690

Model No.

EC-3104-VF05-HG


Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

3

	ITEM NO.	SALES NO.	DESCRIPTION					
	1	015425-45	Vandal Resistant Key					
	2	B-0199-08-N05	0.5 GPM VR Spray Device, 13/16-27 Male Inlet Hose, Faucet, 1/2" NPSM-F x 1/4" NPSM-F ChekPoint Electronic Module (Grey)					
	3	016297-45						
	4	016647-45						
	5	5EF-0002	A/C Transformer					
	6	5EF-0005	Supply Hose, 9/16-24 Female x 1/2" NPSM					
	7	5EF-0006	Mechanical Mixing Valve					
	8	017195-45	Angled Sensor w/ Cable					
	9	EC-FILTER	Replacement Filter					
	10	EC-HYDROGEN-LF	Low Flow Hydro-Generator					
15								

A Maximum of (8) ChekPoint Faucets can be Hardwire Connected and Powered by EC-HARDWIRE ChekPoint Hardwire AC Transformer. (Sold Separately)



Label for Flow Control Switch Settings is Located on Inside of Back Cover.

Flow Control Switches are Located Inside Module Housing in Black Box Next to Battery Compartment. *Switches are Set to DEFAULT Position:

- Auto Time Out = 15 Seconds
- Shut Off Delay = 1 Second
- Auto Flush = ÓFF

Remove (4) Screws and Back Cover to Access Switches.

*Available Water Flow Control Selections:

- Auto Time Out: 15 sec, 30 sec, 45 sec, 60 sec, 3 min, 20 min - Shut Off Delay: 1 sec, 10 sec, 15 sec, 30 sec

(9)

- Auto Flush (30 Seconds After Every 12 Inactive Hours): ON or OFF

Product Compliance: Product Specifications: Chrome Plated Brass Electronic Faucet: 4" Deck Mount Cast Spout w/ VR ASME A112.18.1 / CSA B125.1 0.5 GPM Non-Aerated Spray Device, AC/DC Control Module w/ Internal Flow NSF 61 - Section 9 NSF 372 (Low Lead Content) Control Setting Switches, Temperature Control Mixing Valve w/ Check Valves, Hydro-Generator & 18" Flexible Stainless Steel Supply Hoses ANSI A117.1 (ADA) UL 1951

Drawn:	GEF	Checked:	DMH	Approved:	JHB	Date:	12/05/18	Scale:	NTS	Sheet: 2 of 2

5