



T&S BRASS AND BRONZE WORKS, INC.
 2 Saddleback Cove / P.O. Box 1088
 Travelers Rest, SC 29690



Model No.
EW-7611

Item No.

Travelers Rest, SC: 800-476-4103 • Simi Valley, CA: 800-423-0150 • Fax: 864-834-3518 • www.tsbrass.com

This Space for Architect/Engineer Approval

Job Name _____ Date _____
 Model Specified _____ Quantity _____
 Customer/Wholesaler _____
 Contractor _____
 Architect/Engineer _____



Notes:

1. The ANSI Standard Z358.1 Specifies Eyewash Nozzle Height to be Installed 33" [838mm] to 45" [1143mm] Above the Floor
2. Install so that Eyewash Heads are Over Sink When Activated
3. Drill One ϕ 1 3/8" [25mm] Hole Where Unit is to be Installed
4. These Dimensions May Vary \pm 1/4" [6.4mm]
5. See Installation Instructions for Left Hand Mounting

Product Specifications:
 Deck Mounted Swing Away Eyewash

Product Compliance:
 ANSI Z358.1 (Latest Revision)
 NSF 61 Exempt (Non-Potable)